



**NOTES:**

1. SERVICE CONNECTION AT THE MAIN SHALL BE MADE IN ACCORDANCE WITH SECTION 02610 OF THE SPECIFICATIONS.
2. DO NOT PLACE CURB BOX IN PAVED AREAS.
3. ALL SERVICE CONNECTIONS SHALL BE LOCATED AT THE MIDPOINT BETWEEN LOT LINES.
4. FOR SERVICE CONNECTIONS TO EXISTING BUILDINGS LOCATE CURB BOX 2'-6" FROM EDGE OF CARTWAY. WHERE SIDEWALK EXISTS, LOCATE CURB BOX BETWEEN CURB AND SIDEWALK. WHERE NO CURB EXISTS, THE LOCATION OF THE CURB BOX SHALL BE AS DIRECTED BY TOWNSHIP.
5. PROVIDE PIPE BEDDING AS SHOWN ON STANDARD DETAIL M1

**TYPICAL WATER SERVICE CONNECTION**

N.T.S.

**WARRINGTON TOWNSHIP  
STANDARD DETAIL W1**